

ADDENDUM # 1

Tuesday, May 12, 2015

20150519 PORTABLE RELOCATION

This addendum is a supplement to the electrical requirements stated in the 20150519 Portable Relocation specifications.

All electrical services to the re-located portable classrooms (portables) are to be included in the bid. This includes underground trenching up to 200 linear feet, conduit, wiring, and all associated hardware and materials required for a complete installation from the power source supplied by the local electric utility provider to the electrical panel inside the portables.